



REVISIONS:

- 3/24/04
- 4/1/04
- 4/11/04
- 4/14/04
- 4/28/04

NOTES:

1. Top of the landing slab must be within  $\pm 1/2'$  of finished floor grade.
2. Landing slab must be sloped away from front of house to insure proper drainage.
3. Although not required, a covered landing is highly recommended in order to increase safety and functionality of the entrance.
4. Proper soil compaction is imperative to reducing settlement of landing and adjoining sidewalks. Approved compaction methods should be used.



Scale: 1" = 10'

Developed By: Fred W. Peters  
 Drawn By: Fred W. Peters

PHRC: \_\_\_\_\_  
 HYD/LIFT: \_\_\_\_\_

Front Elevation (Landing)

R101.3-5/26/04